

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3725-0610:134

Page 1 of 1

**CATEGORY:** Door Hardware (Fire-Rated)

**LISTEE:** Dorma Door Controls, Drawer AC, Reamstown, PA 17567  
Contact: Rick Loose (717) 336-3881 Fax (717) 336-2106

**DESIGN:** Models F9500 and ESF9500 Series single point mortise latch type fire exit hardware. This hardware consists of a single mortise latch and a push bar assembly. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed fire exit hardware for use with swinging type fire doors (3/4, 1-1/2, and 3 Hrs) measuring up to 4' in width by 5' in high (single) and 8' in width by 10' in high (double) where permitted per code.

05-27-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager